

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943490-9000	Liquiphant M FTL50 FTL50-GCG2AA8G5A	1	ST

010	Approval:	G	ATEX II 1/2GD Ex ia IIC T6/IECEx zone0/1
020	Process Connection:	CG2	DN50 PN25/40 B1, 316L flange EN1092-1 (DIN2527 C)
030	Probe Length; Type:	AA	Compact; Ra<3.2um/126uin
040	Electronics; Output:	8	FEL58;SIL NAMUR+test button (H-L signal)
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	A	Basic version