

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943491-9000	Liquiphant M FTL51 FTL51-AGR2DB9G5A	1	ST

010	Approval:	A	Non-hazardous area
020	Process Connection:	GR2	Thread ISO228 G1, 316L
030	Probe Length; Type:	DB	L=type II; 316L, Ra<3.2um/126uin, Switch point = Liquiphant II compact
040	Electronics; Output:	9	Special version, TSP-no. to be spec.
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	A	Basic version