

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017198	Cerabar S PMP71 PMP71-ABA2KB1GAABE	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	B	4-20mA HART; inside + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	2K	2bar/200kPa/30psi abs; 20bar/2MPa/300psi
050	Calibration; Unit:	B	**Customised; see additional spec.
060	Membrane Material:	1	316L
070	Process Connection:	GA	Thread ISO228 G1/2 EN837, 316L
090	Fill Fluid:	A	Silicone oil
100	Additional Option 1:	B	3.1 material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	E	SIL