

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017196	Cerabar S PMC71 PMC71-1BA1CEBAAEA+Z1	1	ST

010	Approval:	1	ATEX II 1/2G Ex ia IIC T6
020	Output; Operating:	B	4-20mA HART; inside + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	1C	100mbar/10kPa/1.5psi gauge; 4bar/400kPa/60psi
050	Calibration; Unit:	E	Customised pressure; see additional spec.
070	Process Connection:	BA	DN25 PN10-40 B1, 316L, flush mount flange EN1092-1 (DIN2527 D)
080	Seal:	A	FKM Viton
100	Additional Option 1:	E	SIL
110	Additional Option 2:	A	Not selected
895	>>Marking:	Z1	Tagging (TAG), see additional spec.