

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017197	Cerabar S PMP75 PMP75-1BA2PB1B3GBA	1	ST

010	Approval:	1	ATEX II 1/2G Ex ia IIC T6
020	Output; Operating:	B	4-20mA HART; inside + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	2P	10bar/1MPa/150psi abs; 40bar/4MPa/600psi
050	Calibration; Unit:	B	**Customised; see additional spec.
060	Membrane Material:	1	316L
070	Process Connection:	B3	DN50 PN10-40 B1, 316L, flush mount, flange EN1092-1 (DIN2527 D)
090	Transmitter Mounting; Fill Fluid:	G	Temperature isolator; high temp. oil
100	Additional Option 1:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	A	Not selected