

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017192	Deltabar S PMD75 PMD75-AAJ7D11DA4B	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	A	4-20mA HART; extern + LCD
030	Housing; Cover Sealing; Cable Entry:	J	T15 Alu IP66/67 NEMA6P; EPDM; M20 gland, T15 = top cover (Ex d > M20 thread)
040	Nominal Range; Cell Material; PN:	7D	100mbar/10kPa/1.5psi; 316L; 160bar/16MPa/2400psi
050	Calibration; Unit:	1	Nominal range; mbar/bar
060	Membrane Material:	1	316L
070	Process Connection:	D	NPT1/4-18 IEC61518 UNF7/16-20, 316L incl. 2 valves, 316L
080	Seal:	A	FKM Viton
100	Additional Option 1:	4	Pressure test, internal procedure, test report
110	Additional Option 2:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate