

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943491-9000	Liquiphant M FTL51 FTL51-FBN2BB6G5C	1	ST

010	Approval:	F	ATEX II 1/2GD Ex ia IIC T6, WHG/IECEEx zone 0/1
020	Process Connection:	BN2	DN80 PN25/40 A, 316L flange EN1092-1 (DIN2527 B)
030	Probe Length; Type:	BB	250 mm mm; 316L, Ra<3.2um/126uin
040	Electronics; Output:	6	FEL56; SIL NAMUR (L-H signal)
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	C	EN10204-3.1 material (wetted parts), inspection certificate