

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
71197720	Prowirl F 200, 7F2B1H, DN100 4" 7F2B1H-B2BCCA1D2SK	1	ST

010	Approval:	B2	ATEX II 1/2G Ex ia, II2D Ex tb IIIC
020	Output; Input:	B	4-20mA HART, pulse/freq./switch output
030	Display; Operation:	C	SD02 4-line; push buttons + data backup function
040	Housing:	C	GT20 dual compartment, alu, coated
050	Electrical connection:	A	Gland M20
060	Sensor Version:	1	Volume flow basic, 316L, -40...+260oC/-40...+500oF
070	Process Connection:	D2S	PN40, flange EN1092-1-B1 (DIN2501)
080	Calibration Flow:	K	0.75% volume 3-point